



Primer:

Protok vode 28 m³/h
 Temperatura ulazne vode T_{w1} 32°C
 Temperatura izlazne vode T_{w2} 24°C
 Temperaturna razlika 8 K
 Temperatura vlažnog termometra T_i 18°C

Izabrana rashladna kula EWK 225/06

ESOTEH d.o.o.
 Kolarčeva 8
 11000 Beograd

Dijagram za izbor tipa i
 veličine rashladne
 kule tipa EWK

Rashladne kule
 EWK 036 ÷ 441

