



Primer:

Protok vode	162 m ³ /h
Temperatura ulazne vode T _{w1}	31°C
Temperatura izlazne vode T _{w2}	26°C
Temperaturna razlika	5 K
Temperatura vlažnog termometra T _f	18°C
Izabrana rashladna kula	EWK 630/03

ESOTEH d.o.o.
Kolarčeva 8
11000 Beograd

Dijagram za izbor tipa i
veličine rashladne
kule tipa EWK

Rashladne kule
EWK 630

