



**Primer:**

Protok vode	110 m³/h
Temperatura ulazne vode Tw <sub>1</sub>	31°C
Temperatura izlazne vode Tw <sub>2</sub>	26°C
Temperaturna razlika	5 K
Temperatura vlažnog termometra Tf	18°C
<b>Izabrana rashladna kula</b>	<b>EWB 4600/03</b>

<p><b>ESOTEH d.o.o.</b> Kolarčeva 8 11000 Beograd</p>	<p>Dijagram za izbor tipa i veličine rashladne kule tipa EWB</p>	<p>Rashladne kule EWB 3460 ÷ 7200</p>
---	--	---

